

## 2022 ANNUAL DRINKING WATER QUALITY REPORT

PWSID #: 6170053 NAME: Sandy Township

*Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda.* (This report contains important information about your drinking water. Have someone translate it for you, or speak with someone who understands it.)

### **WATER SYSTEM INFORMATION:**

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact Mr. Shawn Arbaugh, Manager at the Sandy Township Municipal Building in DuBois, PA. We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. They are held the first and third Mondays of each month beginning at 7:00 PM at the Sandy Township Municipal Building, 1094 Chestnut Ave., DuBois, PA 15801.

### **SOURCE(S) OF WATER:**

Our water source is: A bulk purchase from the City of DuBois Water System (PWSID # 6170016) that has as its source, a reservoir located on Anderson Creek in Union Township, Clearfield County, Pennsylvania. Additional groundwater sources include four water wells, located in Sandy Township, that were put online in 2015 to supplement the City's existing water supply.

A *Source Water Assessment* of our source(s) was completed by the PA Department of Environmental Protection (Pa. DEP). The Assessment has found that the most significant potential sources of contamination within the watershed that contributes water to the Anderson Creek Reservoir are transportation corridors, stormwater runoff from agricultural fields, lawn care and golf courses, and malfunctioning on-lot waste disposal. Overall, the watershed contributing raw water to the purification plant has little risk of significant contamination. A summary report of the Assessment is available on the *Source Water Assessment & Protection Web page* at (<http://www.dep.state.pa.us/dep/deputate/watermgt/wc/Subjects/SrceProt/SourceAssessment/default.htm>). Complete reports were distributed to municipalities, water supplier, local planning agencies and PADEP offices. Copies of the complete report are available for review at the Pa. DEP NorthCentral Regional Office, Records Management Unit at (570) 327-3565.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the *Safe Drinking Water Hotline* (800-426-4791).

## MONITORING YOUR WATER:

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2021. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

### DEFINITIONS:

*Action Level (AL)* - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Running Annual Average (RAA)* – A method used to calculate the average of samples collected over a 12 month period. The highest number is reported to determine a violation.

*ppb* = parts per billion, or micrograms per liter (µg/L)

*ppm* = parts per million, or milligrams per liter (mg/L)

### DETECTED SAMPLE RESULTS:

| <b>Chemical Contaminants</b> |                  |         |                |                     |       |                |               |  |
|------------------------------|------------------|---------|----------------|---------------------|-------|----------------|---------------|--|
| Contaminant                  | MCL in CCR Units | MCLG    | Level Detected | Range of Detections | Units | Sample Date    | Violation Y/N | Sources of Contamination                 |
| Free Chlorine                | MRDL=4           | MRDLG=4 | 1.01 Avg.      | 0.37 – 1.70         | MG/L  | Weekly 2022    | N             | Water Additive to control Microbes.      |
| TTHM                         | 80               | N/A     | 50.575 RAA.    | 25.4 – 80.1         | ppb   | Quarterly 2022 | N             | Byproduct of drinking water chlorination |
| HAA5                         | 60               | N/A     | 50.4 RAA.      | 38.7 – 61.3         | ppb   | Quarterly 2022 | N             | Byproduct of drinking water chlorination |

| <b>Lead and Copper</b> |                   |      |                                   |       |                                    |             |               |                                  |
|------------------------|-------------------|------|-----------------------------------|-------|------------------------------------|-------------|---------------|----------------------------------|
| Contaminant            | Action Level (AL) | MCLG | 90 <sup>th</sup> Percentile Value | Units | # of Sites Above AL of Total Sites | Sample Date | Violation Y/N | Sources of Contamination         |
| Lead                   | 0.015             | 0    | 0.000939                          | ppb   | 0 out of 10                        | June 2022   | N             | Corrosion of household plumbing. |
| Copper                 | 1.3               | 1.3  | 0.155                             | ppm   | 0 out of 10                        | June 2022   | N             |                                  |

| <b>Microbial</b>                          |                                     |             |   |                      |                                       |
|---|-------------------------------------|-------------|---|----------------------|---------------------------------------|
| <b>Contaminants</b>                       | <b>MCL</b>                          | <b>MCLG</b> | <b>Highest # or % of Positive Samples</b> | <b>Violation Y/N</b> | <b>Sources of Contamination</b>       |
| Total Coliform Bacteria                   | More than 1 positive monthly sample | 0           | 0   | N                    | Naturally present in the environment. |
| Fecal Coliform Bacteria or <i>E. coli</i> | 0                                   | 0           | 0   | N                    | Human and animal fecal waste.         |

**EDUCATIONAL INFORMATION:**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's *Safe Drinking Water Hotline* (800-426-4791).

**Information about Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Sandy Township is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

***OTHER INFORMATION:***

For a paper copy of this report, or any questions you may have about water quality please call or write the Sandy Township Municipal Building at:

Sandy Township  
PO Box 267  
1094 Chestnut Ave.  
DuBois, PA 15801  
814.371.4220